



**REPORT OF
SANITARIAN VISIT (Nursing Home)**
LHS 37 (DH 7037) (Rev. 6/88)

FACILITY NAME	PARISH
---------------	--------

OPERATOR/OWNER

FACILITY ADDRESS

NO. OF PATIENTS, MALE	NO. OF PATIENTS, FEMALE	APPROVED POPULATION	LICENSE NO.	EXPIRATION DATE
-----------------------	-------------------------	---------------------	-------------	-----------------

An inspection of your premises has this day been made, and you are notified of the defects marked below with a cross (X). Violation of the same item on two successive inspections places your license liable to suspension for violation of the Minimum Standards for Nursing Homes.

ITEM	DEFECT	REMARKS AND/OR RECOMMENDATIONS
1. Heating Equipment - 20:003		
a. Adequate to maintain temperature of not less than 76°F		
b. Heater or duct in each bath/shower room		
c. All combustion heaters vented		
2. Structure - sound, maintained - 20:004		
3. Stairs - treads with non-slip surfaces - 20:005		
4. Bedrooms		
a. Floors, walls and ceilings smooth and easily cleanable - 20:006		
b. Min. 10 foot candles illum. at 30" above floor		
c. Min. 30 foot candles for reading or close work - 20:007		
d. Windows opening to outside - 20:008		
e. Beds: clean linens, moisture proof covers - 20:009		
f. Provision for laundering linens and patients' clothing - 20:009		
5. Bathrooms - 20:010		
a. Lavatory in or adjacent to each room - 20:010-1		
b. One toilet/8 patients (1/10 if operating prior to 5/21/74) - 20:010-1		
c. One tub or shower/10 patients (1/15 if operating prior to 5/21/74) - 20:010-1		
d. Facilities for washing and sanitizing bedpans, urinals, etc. - 20:010-2		
e. Well lighted and vented to outside - 20:010-3		
f. Fixtures of satisfactory type and design - 20:010-3		
g. Tub and/or shower bottoms of non-slip material - 20:010-4		
h. Grab bars at all patient tubs, showers and water closets - 20:010-4-6		
i. Wall switches out of reach of tubs or showers - 20:010-5		
6. Nurse's Station: sink, work space, medicine storage - 20:011		
7. Food Service: meets regulations of Chapter XXIII - 20:012		
8. Water Supply: meets regulations of Chapter XII - 20:013		
9. Sewage and Waste Disposal: meets regulations of Chapter XIII - 20:014		
10. Plumbing: meets regulations of Chapter XIV - 20:015		
11. Employee and Patient Health: meets regulations of Chapters I and II - 20:016		

DATE _____ SANITARIAN _____

--	--	--	--

Administration is aware of employee health requirements of Chapter I, Section 1:008 and Chapter II, Section 2:01-2:024, of the State Sanitary Code and claims compliance.

Owner/Operator